

# **LEROY PALMER & ASSOCIATES PTY LTD**

## **CONSULTING ENGINEERS**

ACN 078 229 526 ABN 28 141 341 900

**Structural Engineering  
Civil Engineering  
Building Consultants  
Project Management  
Geotechnical Engineering  
Subdivision Consultants**

**138 Margaret Street  
PO Box 1413  
Toowoomba 4350  
Phone: (07) 4638 7655  
Fax: (07) 4638 7633  
Mobile: 0417 768 338**

---

5 August 2002

REF: 2500L01

ALQUIP  
720 Greenwattle Street  
Toowoomba 4350

ATTENTION: Mr. Mark Evenden

Dear Mark

### **220 SERIES SCAFFOLDS** **STABILITY OF FREESTANDING SCAFFOLDS**

We hereby certify that the ALQUIP 3 metre long by 1.3 metre wide by 10.2 metre Platform Height Aluminium Scaffold with extra wide base satisfies the requirements of Clause 2.7 of AS/NZS 1576.1:1995 "Stability of Freestanding Scaffolds".

We have witnessed a load test of the above mentioned Scaffold subjected to the loads specified in Clause 2.7 of AS/NZS 1576.1:1995. The Scaffold tested was set up in a ready-to-use condition (i.e. a working condition) and subjected to the required mandatory de-stabilising loads.

Yours sincerely



Leroy Palmer  
B.Eng Civil, GradIEAust, RPEQ 5208